

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3774-1556:100

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Folger Adam Security Inc., 1902 Airport Rd., Monroe, NC, 28110
Contact: *Jeff Trull (704) 283-2101 Ext 252

DESIGN: Models 9901DELM-S, 9901DELM-D, 9901DELM-T, 9911DELM-S, 9911DELM-D and 9911DELM-T delayed egress locking magnet, with or without option BA, DPS, ATS, LK, PS, AUD or Y. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as auxiliary locking device for fire-rated and non fire-rated doors to prevent unwanted entry and unauthorized exit when installed in accordance with the California Building Code, Section 1003.3.1.10 Special egress-control devices. Authority having jurisdiction shall be consulted prior to installation.

XLf: 3774-0324:103

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager